Building Department
143 Third Street, NW, Suite 1
Pulaski, Virginia 24301
(540) 980-7710
(540) 980-7717 (fax)

September 4, 2012

2009 Virginia Energy Conservation Code 403.2.2 Sealing (Mandatory). All ducts, air handlers, filter boxes, and building cavities used as ducts shall be sealed. Joints and seams shall comply with Section M1601.4.1 of the International Residential Code. Verification of compliance with this section shall be in accordance with either Section 403.2.2.1 or 403.2.2.2.

Please indicate which option you used, date tested, and sign below in the presence of a notary. (Pulaski County Building Permit Technicians are Virginia Notaries)

This original form will need to be returned to the Building Official's office prior to scheduling a final inspection.

Building Permit Number _____ **Address** _____
Property Owner Name _____

- ☐ **Postconstruction test:** Leakage to outdoors shall be less than or equal to 8 cfm (226.5 L/min) per 100 ft^2 (9.29 m^2) of conditioned floor area or a total leakage less than or equal to 12 cfm (12 L/min) per 100 ft^2 (9.29 m^2) of conditioned floor area when tested at a pressure differential of 0.1 inches w.g. (25 Pa) across the entire system, including the manufacturer's air handler enclosure. All register boots shall be taped or otherwise sealed during the test.
  Date Tested: _____
- ☐ **Rough-in test:** Total leakage shall be less than or equal to 6 cfm (169.9 L/min) per 100 ft^2 (9.29 m^2) of conditioned floor area when tested at a pressure differential of 0.1 inches w.g. (25 Pa) across the roughed in system, including the manufacturer's air handler enclosure. All register boots shall be taped or otherwise sealed during the test. If the air handler is not installed at the time of the test, total leakage shall be less than or equal to 4 cfm (113.3 L/min) per 100 ft^2 (9.29 m^2) of conditioned floor area.
  Date Tested: _____

Exception: Duct tightness test is not required if the air handler and all ducts are located within conditioned space.

_____ _____
Signature of Contractor/Business Representative Printed Name

_____

I _____, a notary public in and for the Commonwealth of Virginia, County of _____, whose commission will expire on _____ do hereby certify that _____ has acknowledged the same before me in my state and county aforesaid. Given under my hand this _____ day of _____, 2013.

_____ Notary Public Signature

_____ Notary Registration Number